

Mike Wu Guangzhou Zhengkang Medical Equipment Co., Ltd. Room 101, No. 9, Zhongxintang Rd, Nanling, Taihe Town, Baiyun District Guangzhou City, 510000 CHINA

Sponsor:

Dry Microbial Penetration Test Final Report

Test Article: Product Name:Disposable Medical Protective Gown

Model:ZKF-01

Lot No:2020080503

Purchase Order: QHT20080426 Study Number: 1340489-S01 Study Received Date: 11 Sep 2020

Testing Facility: Nelson Laboratories, LLC

6280 S. Redwood Rd.

Salt Lake City, UT 84123 U.S.A.

Test Procedure(s): Standard Test Protocol (STP) Number: STP0191 Rev 06

Deviation(s): None

Summary: This procedure was performed to determine the migration of bacteria carried by organic or inorganic particles through a barrier material in a dry state. Test articles were conditioned then challenged with 0.5 ± 0.1 g bacteria carrying talc particles at a concentration of $>10^8$ colony forming units (CFU)/g. Test articles were vibrated at a level of 19,800–21,900 vibrations per minute (vpm) for 30 minutes. Sedimentation plates placed under the test articles during testing were counted after incubation, and the average counts and log of the average were calculated.

Testing was conducted in compliance with ISO 22612:2005 with the following exceptions. ISO 22612:2005 indicates testing should take place at $65 \pm 5\%$ relative humidity (RH) and $20 \pm 2^{\circ}$ C, instead the test articles were conditioned at these parameters for a minimum of 24 hours, and the testing took place at the conditions indicated below. Additional tolerance was given for incubation time and temperature (24-48 hours at 30-35°C), and vibration frequency (19,800–21,900 vpm). Furthermore, an alternate method for dryness verification (weight verification omitted) may be used. The individual changes were shown to be equivalent to ISO 22612 through internal validation.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Outside

Test Article Preparation: ~200 x 200 mm squares were aseptically cut from the Less Critical

Area of the Material at Random

Conditioning Parameters: 65 ± 5% RH and 20 ± 2°C for a minimum of 24 hours

Air Pressure: 6.0 Bar

Talc Challenge Titer: 2.7 x 10⁸ CFU/g

Negative Control Count: <1 CFU
Temperature: 23.2°C





Janelle Bentz electronically approved

Janelle Bentz

09 Oct 2020 16:32 (+00:00)
Study Completion Date and Time

hch

Study Director

FRT0191-0001 Rev 6 Page 1 of 2



Relative Humidity: 24%

esults:

Test Article Number	Penetration (CFU Recovered)
1	0
2	0
3	0
4	0
5	0
6	0
7	0
8	0
9	0
10	0
Average	<1
Log ₁₀ CFU Average	≤1

Interpretation of Results:

EN13795:

Unit Standa		erformance	High performance	
Critical Area	Critical Area	Less Critical Area	Critical Area	Less Critical Area
CFU	Not Required	≤ 300	Not Required	≤ 300

EN14126:

Class	Penetration (log CFU)
3	≤ 1
2	1 < log CFU ≤ 2
1	2 < log CFU ≤ 3